



Industrie Service

Certificate No. **AM VR2 – 1507 – 139 EU**

TÜV SÜD Industrie Service GmbH, Test Body for Vapour Recovery Systems,
Westendstr. 199, D-80686 Munich



hereby certifies that it has tested the following automatic monitoring system for petrol vapour recovery systems according to EN 16321-1, Appendix D:

Type of system:	Automatic monitoring system with central assessment All assessments, e. g. validity of the refuelling, vapour/petrol ratio are executed by PSS 5000. VAPORIX-Control is supplying data to the PSS 5000.	
Product name:	PSS 5000 in combination with VAPORIX	
Manufacturers:	FAFNIR GmbH	Gas flow sensor and control unit
	DOMS ApS	Forecourt controller
System components:	VAPORIX-Flow	Gas flow sensor
	VAPORIX-Control	Control unit
	PSS 5000	Forecourt controller

Approved for use with all types of vapour recovery systems

Deactivation time: Triggered by PSS 5000 for all connected fuelling points

Set by the manufacturer of PSS 5000:
min. 72 h max. 168 h


Indication of the set deactivation time: Enduring label on the electronic housing of PSS 5000 with:
- deactivation time in hours
- country code to ensure the valid deactivation time in the country

Based on ID: "AM VR2 – 1507 – 139 EU"

The monitoring system for vapour recovery systems corresponds to the state of the art as defined in "Directive 2009/126/EC" last amended by Directive 2014/99/EU"

Germany, Munich, 09/11/2018

Valid to 09/11/2020



Test Body for Vapour Recovery Systems

Peter Szalata

Peter Szalata



24.10.2018
10936
EQ2887037